Energy performance certificate (EPC)

10 Mayfield Link NEWTOWNABBEY BT36 4AW Energy rating

Valid until: 7 June 2033

Certificate number: 2913-5872-3421-9573-2008


Property type

A1/A2 Retail and Financial/Professional services

Total floor area 562 square metres

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

30 B

If typical of the existing stock

80 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	25.63
Primary energy use (kWh/m2 per year)	139

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/9436-3585-3106-8716-8324).

Who to contact about this certificate

Contacting the assessor

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Martin McLeod
Telephone	07734 870 368
Email	tim@atbecltd.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/023303
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment Employer	ATBEC Ltd
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	20 March 2023

8 June 2023