

Energy performance certificate (EPC)

41-43 Belmont Road BELFAST BT4 2AA	Energy rating	Valid until: 17 May 2036
	G	Certificate number: 7737-3417-7235-8262-0049


Property type	A1/A2 Retail and Financial/Professional services
Total floor area	219 square metres

Energy rating and score

This property's energy rating is G.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	37 B
If typical of the existing stock	99 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	121.03
Primary energy use (kWh/m ² per year)	684

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/5206-6269-0831-5581-0390\)](/energy-certificate/5206-6269-0831-5581-0390).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Eamon Lynch
Telephone	02838 394090
Email	info@360-energy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/023963
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	360 Energy
Employer address	22b High Street, Portadown, Craigavon, BT62 1HZ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 May 2026
Date of certificate	18 May 2026