

Energy performance certificate (EPC)

43 Derriaghy Road LISBURN BT28 3SH	Energy rating G	Valid until: 28 April 2032 <hr/> Certificate number: 1011-5049-0270-4384-3521
--	---------------------------	--

Property type


D2 General Assembly and Leisure plus Night Clubs and Theatres

Total floor area

297 square metres

Energy efficiency rating for this property

This property's current energy rating is G.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built



36 | B

If typical of the existing stock



97 | D

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

207.42

Primary energy use (kWh/m² per year)

1172

▶ [What is primary energy use?](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8157-5716-1343-9736-6265\)](/energy-certificate/8157-5716-1343-9736-6265).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Eamon Lynch

Telephone

02838 394090

Email

info@360-energy.co.uk

Accreditation scheme contact details

Accreditation scheme

Elmhurst Energy Systems Ltd

Assessor ID

EES/023963

Telephone

01455 883 250

Email

enquiries@elmhurstenergy.co.uk

Assessment details

Employer

360 Energy

Employer address

22b High Street, Portadown, Craigavon, BT62 1HZ

Assessor's declaration

The assessor is the owner or director of the organisation dealing with the property transaction.

Date of assessment

27 April 2022

Date of certificate

29 April 2022

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.